

WRAS[®]

Water Regulations Advisory Scheme

This certifies that

CONEX UNIVERSAL LIMITED

has had the undermentioned product examined, tested and found, when correctly installed, to comply with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations/Scottish Water Byelaws.

'B PUSH' RANGE OF PUSH FIT FITTINGS (15MM - 28MM)


This certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Directory (www.wras.co.uk/directory)

The product so mentioned will be listed in the Water Fittings and Materials Directory for a period until:


31 MARCH 2019

1403071

Certificate No.



Chairman, Product Approval Group



Secretary

WRAS
APPROVED
PRODUCT